

BMK
Engineering Consultants
Office F10/F11
33 Riley Road
Pinewood Office Park
Woodmead
Sandton, 2191
Your ref: **B5/2015**
Our ref: MGP 1076

Date:
2015/04/25

Enquiries: MG Phala
Tel +27 11 711 2177
Emergency: 086 0037 566

Att: Leoshan Reddi

PROJECT: Jabulani/Molapo, Soweto.

Your letter dated 19 March 2015 has reference.

Eskom's **SAR JABAVU 88kV Traction Substation**
SAR JABAVU / SAR MIDWAY 1 1 88kV Feeder Conductor
SAR JABAVU / SAR NALEDI 1 88kV Feeder Conductor
CIVIC CENTRE / CIVIC5/2233 1 11kV Feeder from CIVIC CENTRE 11kV SUBSTATION to
CIVIC5/2233 Cable as shown on accompanied plans are affected by the proposed work. The approximate position of these services is indicated on the attached drawing. Please note that the exact position of these services cannot be guaranteed.

Eskom will raise no objection to this application provided it's rights and services are acknowledged and respected at all times, and the requirements as laid down by the Occupational Health and Safety Act No 85/1993, are complied with. As additional safety measures Eskom require that the following conditions are complied with:

1. The applicant or his contractor must notify Eskom **Zola & Klipspruit Technical Service Centre at (011) 933 4432 & 933 1114** at least seven (7) days prior to the commencement of any work whatsoever, under or in close proximity to Eskom services.
2. Please note that, under no circumstances will any relocation work proceed prior to the submission of a formal application to **Eskom Customer Services** and acceptance of the relocation costs by the applicant. A formal application for the relocation of Eskom services must be submitted at least **three months** prior to the commencement of any construction work
3. Any cost and claims due to interruptions or interference to Eskom services causing power supply loss or loss of income, due to this application, will be borne by the applicant.
4. Eskom must have ingress to and egress from its services at all times.


5. No mechanical equipment, including mechanical excavators, may be used under or in close proximity to Eskom services without the prior approval of Eskom authorized representatives.
6. The consent is further subject to the Landowner's permission for the proposed works as per this application. A copy of the permission must be filed with Eskom seven days before any work is carried out in the servitude area.
7. Eskom shall not be liable for the death of or injury to any person or for the loss of or damage to any property caused in whatsoever manner by the applicant, his employees, agents or contractors. The applicant indemnifies Eskom against all claims including claims for consequential damages by third parties which includes but is not limited to claims as a result of damage to, or interruption of or interference with Eskom services or equipment. The applicant's attention is drawn to section 27(3) of the Electricity Act 1987.
8. No excavations may be executed closer than **six meters** from overhead lines and **1.5 meters** from underground cables, unless Eskom authorized representative is on site.
9. No blasting may be undertaken under or in close proximity of Eskom services unless minimum charges with adequate matting is used, and then only under the strict supervision of Eskom authorized representatives who require at least three days prior notification.
10. Should the applicant or his contractor damage any of Eskom services during commencement of any work whatsoever, then Eskom 24 hour Fault number **0860 110 124** must be dialled immediately to report the incident.
11. The contractor in charge of the construction or maintenance work on site must at all times be in possession of the letter of approval of the service concerned, and as well as all plans that are required and that are referred to in the correspondence, so that during an inspection the contractor can present the documentation to Eskom official(s) when requested to do so. If no approval can be presented then the Eskom official(s) can order the contractor to cease all works until such approval can be presented.

This approval becomes automatically withdrawn without further rectification and becomes null and void if:

- The applicant does not comply with any of the conditions stipulated above:
- Eskom has not received a written acceptance of the abovementioned conditions within thirty days of date of this letter, before commencement of any work by the applicant, and
- The stated works are not started within a period of 180 days from date of this letter.

Please acknowledge receipt of this letter.

Yours faithfully



M.G. Phala (MR)
for : LAND DEVELOPMENT MANAGER